

STATE OF WASHINGTON  
DEPARTMENT OF ECOLOGY

**PERMIT**

TO APPROPRIATE PUBLIC WATERS OF THE STATE OF WASHINGTON

☐

Surface Water

(Issued in accordance with the provisions of Chapter 117, Laws of Washington for 1917, and amendments thereto, and the rules and regulations of the Department of Ecology.)

☒

Ground Water

(Issued in accordance with the provisions of Chapter 263, Laws of Washington for 1945, and amendments thereto, and the rules and regulations of the Department of Ecology.)

PRIORITY DATE	APPLICATION NUMBER	PERMIT NUMBER	CERTIFICATE NUMBER
December 19, 1991	G2-28355	G2-28355	

NAME

Fawn Lake Maintenance Association

ADDRESS (STREET)

471 SE Crescent Drive

(CITY)

Shelton

(STATE)

Washington

(ZIP CODE)

98584-9211

The applicant is, pursuant to the Report of Examination which has been accepted by the applicant, hereby granted a permit to appropriate the following described public waters of the State of Washington, subject to existing rights and to the limitations and provisions set out herein.

**PUBLIC WATERS TO BE APPROPRIATED**

SOURCE

Well #4

TRIBUTARY OF (IF SURFACE WATERS)

MAXIMUM CUBIC FEET PER SECOND

MAXIMUM GALLONS PER MINUTE

200

MAXIMUM ACRE-FEET PER YEAR

195

QUANTITY, TYPE OF USE, PERIOD OF USE

70 acre-feet per year

Multiple domestic supply

Year-round, as needed

(Primary)

\*125 acre-feet per year

(supplemental)\*

**LOCATION OF DIVERSION/WITHDRAWAL**

APPROXIMATE LOCATION OF DIVERSION-WITHDRAWAL

400 feet south and 550 feet west of the east quarter corner of Section 5.

LOCATED WITHIN (SMALLEST LEGAL SUBDIVISION)

NE¼ SE¼

SECTION

5

TOWNSHIP N.

19

RANGE, (E. OR W.) W.M.

3W

W.R.L.A.

14

COUNTY

Mason

**RECORDED PLATTED PROPERTY**

LOT

BLOCK

OF (GIVE NAME OF PLAT OR ADDITION)

**LEGAL DESCRIPTION OF PROPERTY ON WHICH WATER IS TO BE USED**

Plats of Fawn Lake, Divisions 1 through 6.

# DESCRIPTION OF PROPOSED WORKS

Proposed 10-inch cased well. Anticipate 150 to 200 gpm.

## DEVELOPMENT SCHEDULE

BEGIN PROJECT BY THIS DATE:

April 1, 1994

COMPLETE PROJECT BY THIS DATE:

April 1, 1995

WATER PUT TO FULL USE BY THIS DATE:

April 1, 1996

April 1, 2010

## PROVISIONS

"The total annual withdrawal under all domestic water rights for Fawn Lake Maintenance Association shall not exceed 195 acre-feet per year."

Installation and maintenance of an access port as described in WAC 173-160-355 is required. An air line and gauge may be installed in addition to the access port.

All water wells constructed within the State shall meet the minimum standards for well construction and maintenance as provided under RCW 18.104, Washington Water Well Construction Act of 1972, and Chapter 173-160 WAC, Minimum Standards for Construction and Maintenance of Wells.

In accordance with WAC 173-160-205, wells shall not be located within certain minimum distances of potential sources of contamination. These minimum distances shall comply with local health regulations, as appropriate. In general, wells shall be located at least 100 feet from a sewer, septic tank, privy, or other source of contamination. Wells shall not be located within 1,000 feet of a solid waste landfill.

The Permittee is advised that notice of proof of appropriation of water (under which the final certificate of water right is issued) should not be filed until the permanent diversion facilities have been installed, and the system is currently in use. This includes installation of a mainline system capable of delivering the recommended quantity of water to an existing or proposed distribution system within the area to be served, and fulfillment of all other terms of this permit.

"The final withdrawal rate will be based on system capacity and may be reduced prior to issuance of the water right certificate."

An approved metering device shall be installed and maintained in accordance with RCW 90.03.360, WAC 508-64-020 through -040. Meter readings shall be recorded at least monthly.

This permit is subject to the implementation of the minimum requirements established in the Interim Guidelines for Public Water Systems Regarding Water Use Reporting, Demand Forecasting Methodology and Conservation Programs, July 1990.

*This permit shall be subject to cancellation should the permittee fail to comply with the above development schedule and/or fail to give notice to the Department of Ecology on forms provided by that Department documenting such compliance.*

*Given under my hand and the seal of this office at Olympia, Washington,*

this 15th day of December, 19 93.

Mary Riveland, Director

Department of Ecology

ENGINEERING DATA

OK MP

by Gale Blomstrom

PERMIT

Provisions Continued

Under RCW 90.03.005 and 90.54.020(6), conservation and improved water use efficiency must be emphasized in the management of the states water resources, and must be considered as a potential new source of water. Accordingly, as part of the terms of this permit, the applicant shall prepare and implement a water conservation plan approved by Department of Health. The standards for such a plan may be obtained from either the Department of Health or the Department of Ecology.

The Water Resources Act of 1971 specifies certain criteria regarding utilization and management of the water of the state in the best public interest. Use of water may be subject to regulation at certain times, based on the necessity to maintain water quantities sufficient for preservation of the natural environment.